



Physical Technical Testing Institute, Ostrava-Radvanice

National testing authority No 210,

Certification body No. 3051 accredited by ČIA Praha

## Certificate No.: FTZÚ 10 E 0023

about verification of IP 65 code

This certificate is issued for **Switchboard, type KAPPA-xx/yy/zz**

Manufacturer: **SENCO Příbram spol. s r.o., Plynářská 292, 261 01 Příbram I, Czech Republic**

Applicant: **SENCO Příbram spol. s r.o., Plynářská 292, 261 01 Příbram I, Czech Republic**

Above mentioned product and any of its variant are specified in Annex of the certificate and in documentation, list of which is attached in Annex of this certificate.

FTZÚ – National testing authority No. 210 confirms, that product comply with requirements following standards:

**EN 60 529:1991; EN 62 208:2004**

Apparatus marking:

**IP 65**

Manufacturer (or applicant) listed in the certificate is responsible for product conformity assurance in accordance with its specification (documentation) listed in Annex of the certificate and for successful performance of all specified routine tests and verification.

Responsible person:

  
Dipl. Ing. Sindler Jaroslav  
Head of certification body



Date of issue: 16.08.2010

Number of pages: 1/1  
Annex: 1

This certificate is valid only for products described in this certificate and doesn't replace any other documents.  
This certificate shall not be reproduced except in full without written approval of authorized entity (FTZÚ).